


An Analysis of a Wind Turbine-Generator System in the Presence of Stochasticity and Fokker-Planck Equations

Ravish Himmatlal Hirpara, S.V. National Institute of Technology (SVNIT), Surat, India

 <https://orcid.org/0000-0003-1222-3562>

Shambhu Nath Sharma, S.V. National Institute of Technology (SVNIT), Surat, India

ABSTRACT

In power systems dynamics and control literature, theoretical and practical aspects of the wind turbine-generator system have received considerable attentions. The evolution equation of the induction machine encompasses a system of three first-order differential equations coupled with two algebraic equations. After accounting for stochasticity in the wind speed, the wind turbine-generator system becomes a stochastic system. That is described by the standard and formal Itô stochastic differential equation. Note that the Itô process is a strong Markov process. The Itô stochasticity of the wind speed is attributed to the Markov modeling of atmospheric turbulence. The article utilizes the Fokker-Planck method, a mathematical stochastic method, to analyse the noise-influenced wind turbine-generator system by doing the following: (i) the authors develop the Fokker-Planck model for the stochastic power system problem considered here; (ii) the Fokker-Planck operator coupled with the Kolmogorov backward operator are exploited to accomplish the noise analysis from the estimation-theoretic viewpoint.

KEYWORDS

Differential Equations (SDEs), Fokker-Planck Technique, Small Scale Turbulence, Stochastic, Wind Turbine-Generator System

1. INTRODUCTION

The wind energy has become one of the popular renewable sources for the generation of the electrical power. Three different configurations are popular in the wind power conversion technology, the fixed speed wind turbine-generator system, the limited variable speed wind turbine-generator system and variable speed wind turbine-generator system. The main components of the fixed speed wind turbine-generator system are wind turbine, gearboxes, squirrel cage induction generator, capacitor. That are connected to the grid through the transformer. This configuration allows the machine to run at the constant speed as well as provides stable frequency. Secondly, the limited variable speed wind turbine-generator system utilizes the wound rotor induction generator in place of the squirrel cage. This structure utilizes a power electronic converter. Thirdly, the variable speed wind turbine-generator system accounts for the doubly-fed induction generator with a power electronic converter (Li and Chen, 2008). Here, some important dynamical equations for the wind turbine-generator system are described. Fu and Xing (2009) have developed a four-dimensional Squirrel Cage Induction Generator (SCIG)

DOI: 10.4018/IJSDA.2020010102

This article, originally published under IGI Global's copyright on January 1, 2020 will proceed with publication as an Open Access article starting on January 25, 2021 in the gold Open Access journal, International Journal of System Dynamics Applications (converted to gold Open Access January 1, 2021), and will be distributed under the terms of the Creative Commons Attribution License (<http://creativecommons.org/licenses/by/4.0/>) which permits unrestricted use, distribution, and production in any medium, provided the author of the original work and original publication source are properly credited.

model. Subsequently, a reduced-order model was developed using singular perturbation method. The singular perturbation method hinges on the electrical engineering assumption that stator transients are faster than rotor transients. Thus, the evolutions of stator transients are not accounted for and the evolutions of rotor transients are accounted for. Taha Hussien et al. (2017) have developed modeling of three phase induction motor and explain stator turns fault analysis based on artificial intelligence. Salima et al. (2018) have developed a Global stability of linearizing control of induction motor for PV water pumping application. To study the control system design using Matlab see (Moysis et al. 2017). Gabhi et al. (2018) have developed discrete sliding mode control scheme for nonlinear systems with bounded uncertainties and Alain et al. (2017) have developed improved robust adaptive control strategy for the finite time synchronization of uncertain nonlinear systems. Feijóo et al. (2000) have considered a third-order deterministic equation that explains modelling of the rotor transient voltages behind the transient impedance. Balanathan et al. (2002) have developed a dynamic load model. That has ability to analyse the transient and steady state stabilities of the induction motor. To study the influence of the wind power dynamics on the large electrical power systems dynamics and control, Slootweg et al. (2003) argue the addition of wind turbine-generating systems' models in software packages, especially for numerical experimentations. In this connection, especially for numerical experimentations of wind turbine models, two articles, i.e. Sorensen et al. (2002) and Nichita et al. (2002), would be also useful. Dusonchet et al. (2007) have investigated the influence of wind turbine mechanical characteristics. The transient voltage stability of the fixed speed wind turbine-generator systems were studied as well. In their investigation, the fifth-and the third-order models were the subject of investigations. Generally, the third-order model is a special case of the fifth-order model. The third-order does not account for stator transients into considerations, see Popović et al. (1998) and Ledesma et al. (2003). Furthermore, Martins et al. (2007) have validated the fifth-and third-order models with measured data, which are rarely reported in literature. The preceding introductory descriptions of this paper suggest that the problem of analysing the wind turbine-generator system from the dynamical systems' viewpoint received considerable attention in literature. Under the wind turbulence influence, it is reasonable to account for the stochastic character of the wind speed for the wind turbine-generator system in lieu of the deterministic formalism. A good discussion about the wind turbine-generator system under stochastic influence can be found in brief research writing, but a compelling paper in stochastic sense (Wang and Crow 2012). The stochastically perturbed dynamical system involves investigations into vector Stochastic Differential Equations (SDEs) in lieu of Ordinary Differential Equations (ODEs). This seems to be one of the reasons that the notion of stochastic processes is relatively very less introduced into 'power systems dynamics' literature yet.

This paper is aimed to account for the stochastic evolution of the wind speed in lieu of the deterministic for the wind turbine-generator system. This paper is inspired from the fact that the systems and control methods under stochastic considerations contribute to the greater accuracy and refinements (Mumford 2000) in available results, see Sinai (1981). Here, a succinct discussion that the Itô stochasticity is imperative for the wind turbine-generator system. The turbulent atmospheric flows influences the wind speed operation, the response time of wind turbines is typically in the range of seconds. Thus, they are subjected to small scale turbulence. The Fokker-Planck analysis for small scale turbulence agree with experimental corroborations (Renner et al. 2001). From the theory of stochastic processes, the Fokker-Planck equation is a consequence of the Itô stochastic differential equation. Thus, the qualitative characteristics of atmospheric turbulence are embedded in the Itô stochastic correction term of the wind speed evolution equation. The major ingredient of this paper, which is utilized to develop the theory of this paper, is the Fokker-Planck equation. The Fokker-Planck equation is an influential result in the theory of stochastic processes and stochastic differential equations. The equation is the evolution of conditional probability density for a given initial state for a Markovian state vector. In Wang and Crow (2012), the 'reduced-order' Fokker-Planck equation for the two-dimensional state comprising the slip and wind speed, was the subject of investigations. In their analysis, the numerical experimentation for the reduced Fokker-Planck equation was accomplished

24 more pages are available in the full version of this document, which may be purchased using the "Add to Cart" button on the publisher's webpage: www.igi-global.com/article/an-analysis-of-a-wind-turbine-generator-system-in-the-presence-of-stochasticity-and-fokker-planck-equations/241312

Related Content

Economic Decision-Making and Risk Management: A Relation From the Banking Perspective

Brian J. Galli (2021). *International Journal of System Dynamics Applications* (pp. 1-25).

www.irma-international.org/article/economic-decision-making-and-risk-management/273886

Peer-to-Peer Orchestration of Web Mashups

Abul Ahsan Md Mahmudul Haque and Weihai Yu (2014). *International Journal of Adaptive, Resilient and Autonomic Systems* (pp. 40-60).

www.irma-international.org/article/peer-to-peer-orchestration-of-web-mashups/118297

A Generic Adaptation Framework for Mobile Communication

Hong Sun, Ning Gui and Chris Blondia (2011). *International Journal of Adaptive, Resilient and Autonomic Systems* (pp. 46-57).

www.irma-international.org/article/generic-adaptation-framework-mobile-communication/51548

Adaptive Neurodynamics

Mario Negrello, Martin Hulse and Frank Pasemann (2008). *Applications of Complex Adaptive Systems* (pp. 85-111).

www.irma-international.org/chapter/adaptive-neurodynamics/5135

Various Extensions for the Ambient OSGi Framework

Stéphane Frénot, Frédéric Le Mouél, Julien Ponge and Guillaume Salagnac (2013). *Innovations and Approaches for Resilient and Adaptive Systems* (pp. 208-219).

www.irma-international.org/chapter/various-extensions-ambient-osgi-framework/68952