

## Chapter 14

# Oil and Gas Storage Tank Risk Analysis

**Katarina Simon**  
*University of Zagreb, Croatia*

### ABSTRACT

*Storage tanks are widely used in the oil refinery and petrochemical industry in storing a multitude of different products ranging from gases, liquids, solids, and mixtures. Design and safety concerns have become a priority due to tank failures causing environment pollution as well as fires and explosions, which can result in injuries and fatalities. The chapter illustrates different types of crude oil and oil product storage tanks as well as the risks regarding the storage itself. Considering that the natural gas, in its gaseous state, is stored in underground storages like oil and gas depleted reservoirs, aquifers or salt caverns, and there are numerous publications and books covering the subject in detail, this chapter only illustrates the storage of liquefied natural gas and the risks posed by its storage.*

### INTRODUCTION

In oil and gas industry the movement of crude and refined oil products from the places of origin to the various markets would not be possible without the existence of economic

and safe storage facilities. Storage tanks are located at the ends of feeder lines and gathering lines, along truck pipelines, at marine loading and unloading facilities and in refineries, terminals and bulk plants.

Oil produced from the early wells was stored in whisky barrels. Barrels, although

DOI: 10.4018/978-1-4666-4777-0.ch014

unsuitable for storage use because of leaking, remained in use for a long time due to their ease of transportation and were eventually replaced by steel ones. The measurement of the oil volume is often expressed in barrels (1 bbl=0,159 m<sup>3</sup>) precisely because of such practices. With the ever growing need for oil, the storage tank sizes increased with time. Today, crude oil is commonly stored in large aboveground atmospheric vertical cylindrical storage tanks at oil fields, terminals and refineries where storage tanks are typically installed with similar or identical vessels in a group.

At the oilfield, when the oil is brought to the surface under high pressure conditions it is passed through either a two (where the associated gas is removed and any oil and water remain together) or a three phase separator (where the associated gas is removed and the oil and water are also separated). The remaining low pressure oil is then directed to a storage vessel where it is stored for a period of time before being transported off-site. The remaining hydrocarbons in the oil are released from the oil as vapours in the storage vessels. At the oil fields produced crude oil is usually stored in fixed roof storage tanks while stabilised oil and oil products at terminals and refineries are stored in floating roofs tanks. Within the European Union (EU) the specification for the design of such tanks is covered by the British Standard BS EN 14015:2004 (2005) which is generally equivalent to American Petroleum Institute (API) standards, API 650 (Welded steel tanks for oil storage, 2007) and API 620 (The design and construction of large, welded, low-pressure storage tanks, 2002).

Terminals are storage facilities which generally receive crude oil and petroleum products by trunk pipeline or marine vessel. Crude oil and petroleum product terminals are designed to receive and dispatch crude oil and petroleum products to refineries, other terminals, bulk plants and consumers by pipelines, railroad tank cars and tank trucks. Tanks should ideally be located alone, but storage tanks are often grouped in tank farms. Within tank farms, individual tanks or groups of two or more tanks are usually surrounded by a catchment area in the form of a retaining wall, known as a bund or dike. Bunds would normally be constructed from earth or preferably concrete and should be largely impervious to liquid and capable of withstanding hydrostatic and hydrodynamic pressures to which they could be subjected. Whenever tanks share a common bund, intermediate walls up to half the height of the main bund walls and no more than 0,5 metres high should be provided to control small spillages from one tank affecting another. Bund floors should drain to a single location complete with sump for the regular removal of water from rainfall or firewater testing. Drains should normally be kept closed, with the drain isolation valve situated outside the bund. Bunds are normally designed to hold 110% of that of the largest tank, the excess height notionally to prevent stored liquid surging over the top of the bund in the event of a catastrophic failure of the primary containment. This allowance has proved to be inadequate as, even with storage volume excess, large quantities of liquid can still overtop bunds as discussed by Thyer and Jagger (2002) and Atherton (2005).

17 more pages are available in the full version of this document, which may be purchased using the "Add to Cart" button on the publisher's webpage:  
[www.igi-global.com/chapter/oil-and-gas-storage-tank-risk-analysis/95684](http://www.igi-global.com/chapter/oil-and-gas-storage-tank-risk-analysis/95684)

## Related Content

---

### Valorisation of Glycerol to Fine Chemicals and Fuels

Nikolaos Dimitratos, Alberto Villa, Carine E. Chan-Thaw, Ceri Hammond and Laura Prati (2016).

*Petrochemical Catalyst Materials, Processes, and Emerging Technologies* (pp. 352-384).

[www.irma-international.org/chapter/valorisation-of-glycerol-to-fine-chemicals-and-fuels/146333](http://www.irma-international.org/chapter/valorisation-of-glycerol-to-fine-chemicals-and-fuels/146333)

### Preparation of Deep Hydrodesulfurization Catalysts for Diesel Fuel using Organic Matrix Decomposition Method

Hamid Audah AlMegren, Sergio Gonzalez-Cortes, Yu Huang, Haoyi Chen, Yangdong Qian, Mohammed

Alkinany, Saud Aldrees and Tiancun Xiao (2016). *Petrochemical Catalyst Materials, Processes, and*

*Emerging Technologies* (pp. 216-253).

[www.irma-international.org/chapter/preparation-of-deep-hydrodesulfurization-catalysts-for-diesel-fuel-using-organic-matrix-decomposition-method/146329](http://www.irma-international.org/chapter/preparation-of-deep-hydrodesulfurization-catalysts-for-diesel-fuel-using-organic-matrix-decomposition-method/146329)

### Review on Fisher-Tropsch Synthesis Method in Liquid Fuel Production: FTS Method in Fuel Production

Rahman Shakibaei Lalehloo, Gomaa A. M. Ali and Hamidreza Sadegh (2020). *Advanced Catalysis*

*Processes in Petrochemicals and Petroleum Refining: Emerging Research and Opportunities* (pp. 96-109).

[www.irma-international.org/chapter/review-on-fisher-tropsch-synthesis-method-in-liquid-fuel-production/238684](http://www.irma-international.org/chapter/review-on-fisher-tropsch-synthesis-method-in-liquid-fuel-production/238684)

### Risk Due to Pipe Sticking

Nediljka Gaurina-Medjimurec and Borivoje Pasic (2014). *Risk Analysis for Prevention of Hazardous*

*Situations in Petroleum and Natural Gas Engineering* (pp. 47-72).

[www.irma-international.org/chapter/risk-due-to-pipe-sticking/95673](http://www.irma-international.org/chapter/risk-due-to-pipe-sticking/95673)

### Palladium in Heterogeneous Oxidation Catalysis

Andreas Martin, Venkata Narayana Kalevaru and Jörg Radnik (2016). *Petrochemical Catalyst Materials,*

*Processes, and Emerging Technologies* (pp. 53-81).

[www.irma-international.org/chapter/palladium-in-heterogeneous-oxidation-catalysis/146323](http://www.irma-international.org/chapter/palladium-in-heterogeneous-oxidation-catalysis/146323)