# Chapter 14 Cuckoo Search Algorithm for Hydrothermal Scheduling Problem

**Thang Trung Nguyen** Ton Duc Thang University, Vietnam

**Dieu Ngoc Vo** Ho Chi Minh City University of Technology, Vietnam

## ABSTRACT

This chapter proposes a Cuckoo Search Algorithm (CSA) and a Modified Cuckoo Search Algorithm (MCSA) for solving short-term hydrothermal scheduling (ST-HTS) problem. The CSA method is a new meta-heuristic algorithm inspired from the obligate brood parasitism of some cuckoo species by laying their eggs in the nests of other host birds of other species for solving optimization problems. In the MCSA method, the eggs are first classified into two groups in which ones with low fitness function are put in top group whereas others with higher fitness function are put in abandoned group. In addition, an updated step size in the MCSA changes and tends to decrease as the iteration increases leading to near global optimal solution. The robustness and effectiveness of the CSA and MCSA are tested on several systems with different objective functions of thermal units. The results obtained by the CSA and MCSA are analyzed and compared have shown that the two methods are favorable for solving short-term hydrothermal scheduling problems.

### INTRODUCTION

Electrical energy is one of the most popular and economic energies due to it's easy production at high performance and it's reasonable cost. Development of a country's economy is partially dependent on the country's electrical energy improvement policy. In fact, most of developing and developed countries are focusing on industry such as producing car, machine, etc. consuming a large number of electricity among total generated energy. Therefore, a main task is to establish electrical power systems which have to works flexibly, continually and economically. Thermal plants using fossil fuel account for large rate

DOI: 10.4018/978-1-4666-9644-0.ch014

power plants among several kinds of electrical power plants including conventional plants like thermal plants and hydro plants, and renewable energy based ones like wind power plants, solar power plants, photovoltaic, etc.

Planning optimal operation of isolated or inter connected power systems show a large variety of challenging problems, the solution of which requires application of several mathematical techniques from various branches of it. In power system optimization operation, there is a set of many available power plants which are being waiting for operation from experts. The task is to determine how many Megawatts each plant should supply to power system gird and transfer to customer load. The problem has been formulated as an optimization problem containing an objective function and equality constraints and inequality constraints. As the objective function is obtained, it means that fuel cost for producing electricity at thermal plants is minimized and all equality constraints and inequality constraints are satisfied over considered schedule time. This problem is defined as an economic load dispatch problem.

For a larger power system, both all thermal plants and hydro plants are connected via transmission line. The optimal operation task of the system has become more complicated since the hydro plants had a significant contribution to total electrical energy supplying to load. In fact, there are several complex constraints in hydro plants including equality constraint such as available water volume and inequality constraints such as upper and lower limits on power output of generator, on water discharges and on reservoir volume. However, the objective function of the hydro plants can be ignored as their primary fuel for producing electricity, water, is considered negligible. Therefore, the objective function of hydrothermal scheduling problem is also to minimize fuel cost of thermal plants while satisfying all constraints of the hydrothermal system such as load balance constraint, available water constraint, maximum and minimum limits on thermal and hydro generations, on water discharge and on volume reservoir.

Several conventional methods have been used to solve the short-term hydrothermal scheduling problem such as Newton method since the end of twentieth century (Zaghlool & Trutt, 1988; Basu, 2003), method based on the combination of Lagrange function and Newton method (Rashid & Nor, 1991), lambda-gamma iteration method (Wood & Wollenberg, 1996), dynamic programming (DP) (Wood & Wollenberg, 1996), gradient search technique (GS) (Wood & Wollenberg, 1996), mixed integer programming (MIP) (Nilsson & Sjelvgren, 1996), decomposition and coordination method (Li, Svoboda, Chung-Li Tseng & Johnson, 1997), Lagrange relaxation (LR) (Salam Nor KM, Hamdan, 1998; Xiaohong, Luh & Zhang, 1995; Al-Agtash, 2001), network flow (Franco, Carvalho & Soares, 1994; Heredia & Nabona, 1995; Oliveira & Soares, 1995), hydrothermal scheduling algorithm (HSA) (Cavalho & Soares, 1987), peak shaving (Simopoulos, Kavatza & Vournas, 2007), and progressive optimality algorithm (Nanda & Bijwe, 1981). The conventional methods have the same characteristic that the objective function and all constraints have to be represented as piecewise linear or differentiable functions. The manner means that applicability of the methods are restricted on problems with more complex objective function considering valve point loading effect and complex constraints.

In recent years, many meta heuristic algorithms have been proposed for solving the HTS problem such as simulated annealing approach (SA) (Wong & Wong, 1994), evolutionary programming (EP) (Yang, Yang & Huang, 1996; Hota, Chakrabarti & Chattopadhyay, 1999; Sinha, Chakrabarti & Chattopadhaya, 2003; Türkay, Mecitoğlu & Baran, 2011), genetic algorithm (GA) (Chan & Chang, 1996; Orero & Irving, 1998; Gil, Bustos & Rudnick, 2003; Sasikala J, Ramaswamy, 2010, Kumar & Naresh, 2007), Hopfield neural network (HNN) (Basu, 2003), differential evolution (DE) (Lakshminarasimman & Subramanian, 2006), particle swarm optimization (PSO) (Yu, Yuan & Wang, 2007, Mandal, Basu &

32 more pages are available in the full version of this document, which may be purchased using the "Add to Cart" button on the publisher's webpage: <u>www.igi-global.com/chapter/cuckoo-search-algorithm-for-hydrothermal-</u> scheduling-problem/147522

## **Related Content**

#### A New Multiagent Algorithm for Dynamic Continuous Optimization

Julien Lepagnot, Amir Nakib, Hamouche Oulhadjand Patrick Siarry (2010). *International Journal of Applied Metaheuristic Computing (pp. 16-38).* www.irma-international.org/article/new-multiagent-algorithm-dynamic-continuous/40906

#### Utilizing Information Technology in Senior Care Franchises

Ye-Sho Chen (2018). International Journal of Computers in Clinical Practice (pp. 48-62). www.irma-international.org/article/utilizing-information-technology-in-senior-care-franchises/217449

#### Al Symphony: Orchestrating Economic Resonance in India and ASEAN Countries

Varnesh Ghildiyal, Mahendra Babu Kuruva, Durgesh Bahugunaand Muskan Singh (2024). Artificial Intelligence and Machine Learning-Powered Smart Finance (pp. 289-302). www.irma-international.org/chapter/ai-symphony/339177

#### On the Value of Aspiration Criteria in Tabu Search

Lars Magnus Hvattum (2016). International Journal of Applied Metaheuristic Computing (pp. 39-49). www.irma-international.org/article/on-the-value-of-aspiration-criteria-in-tabu-search/165026

#### A Biologically-Inspired Metaheuristic Approach for the Simultaneous Generation of Alternatives

Julian Scott Yeomans (2018). International Journal of Computers in Clinical Practice (pp. 1-12). www.irma-international.org/article/a-biologically-inspired-metaheuristic-approach-for-the-simultaneous-generation-ofalternatives/217446